



水務署
Water Supplies Department

總部 Headquarters
香港灣仔告士打道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/2024 T/J(485/2024)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

15 August 2024

**Approval of “PCC” Stainless Steel Fittings
(General Acceptance No. C20240542)**

Your letter ref. 230917PC240030 dated 29 May 2024 and subsequent submissions received by this department up to 23 July 2024 refer.

Having considered the test report ref. 230917PC240030A issued on 24 June 2024 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: PCC (Guangzhou) Piping Technology Industrial Ltd

Country of Origin: the Mainland of China

Brand: PCC

Details of Fittings: Stainless steel fittings with press ends connection (316L)

Description	Model	Size
Equal Tee	1210	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108 (mm)

Description	Model	Size
Tee with Female Threads	1212	15x½"x15, 22x½"x22, 22x¾"x22, 28x½"x28, 28x¾"x28, 28x1"x28, 35x½"x35, 35x¾"x35, 35x1"x35, 42x½"x42, 42x¾"x42, 42x1"x42, 54x½"x54, 54x¾"x54, 54x1"x54, 66.7x¾"x66.7, 76.1x¾"x76.1, 108x¾"x108 (mm x inch x mm)
Tee with Male Threads	1213	22x½"x22, 22x¾"x22, 28x½"x28, 28x1"x28, 54x2"x54 (mm x inch x mm)
Male 90° Tee MxRxF	1214	28x¾"x28, 42x¾"x42, 54x¾"x54, 54x1"x54 (mm x inch x mm)
Big Tee	1215	15x22x15, 22x28x22 (mm)
Pig Tee	1216	15x15x22, 22x22x15, 22x22x28, 28x28x22 (mm)
Reducing Tee	1211	22x15x22, 28x15x28, 28x22x28, 35x15x35, 35x22x35, 35x28x35, 42x15x42, 42x22x42, 42x28x42, 42x35x42, 54x15x54, 54x22x54, 54x28x54, 54x35x54, 54x42x54, 66.7x22x66.7, 66.7x28x66.7, 66.7x35x66.7, 66.7x42x66.7, 66.7x54x66.7, 76.1x22x76.1, 76.1x28x76.1, 76.1x35x76.1, 76.1x42x76.1, 76.1x54x76.1, 76.1x66.7x76.1, 108x22x108, 108x28x108, 108x35x108, 108x42x108, 108x54x108, 108x66.7x108, 108x76.1x108 (mm)

Body Markings: PI size 316L DVGW OL-11

Expiry Date: .10 March 2029

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Equal Tee



Tee with Female
Threads



Tee with Male
Threads



Male 90° Tee
MxRx F



Big Tee



Pig Tee



Reducing Tee